



## Inventory of Items Inspected for: ABC Industries

12/11/2008

Jun-08	Dec-08	Jun-08	Dec-08	Barcode:	Location/Equipment:	Thermograph Report Page #
Open Problems:	Open Problems	Status:	Status:			
					<b>Electric Room #2</b>	
no	no	tested	tested	003144	Main service disconnect #2 of 2	
no	no	tested	tested	003145	Panel HM6	
no	no	tested	tested	003146	Main battery charging system disconnect	
no	no	tested	tested	003147	Panel HM3	
no	no	tested	tested	003148	Xformer to LCB disconnect	
no	no	tested	tested	003149	Panel 6/via transformer TL6H1	
		not-t	not-t	003150	Spare disconnect	
no	no	tested	tested	003151	Panel HC1	
no	no	tested	tested	003152	Panel L3-3	
no	no	tested	tested	003153	Panel L3-2	
no	no	tested	tested	003154	Panel L3-1	
no	no	tested	tested	003155	TL3 transformer	
no	no	tested	tested	003156	Panel HM3-3	
no	yes	tested	tested	003157	Panel HM3-2	2
yes	no	tested	tested	003158	Panel H3-2	
no	no	tested	tested	003159	Panel H3-1	
no	no	tested	tested	N/A	Utility feed	
					<b>Electric Room #1</b>	
no	no	tested	tested	003160	Main disconnect service 31 of 2	
no	no	tested	tested	003161	Panel HM2	
no	no	tested	tested	003162	Panel HM5	
no	no	tested	tested	003163	Panel HM1	
no	no	tested	tested	003164	Panel HM4	
no	no	tested	tested	003165	Panel HLS2	
no	no	tested	tested	003166	Air compressor 2 disconnect	
no	no	tested	tested	003167	East battery charging sys. disconnect	
no		tested	not-t	003168	Air compressor 1 disconnect	locked out
no	no	tested	tested	003169	Panel L2-2	
no	no	tested	tested	003170	Panel L2-1	
no	no	tested	tested	003171	TL-2 transformer	
no	no	tested	tested	003172	Panel HM2-1	
yes	no	tested	tested	003173	Panel HM-2-2	
no	no	tested	tested	003174	Panel H2-1	
no	no	tested	tested	003175	Panel H2-2	
no	no	tested	tested	005515	Panel HLS2	
no	yes	tested	tested	N/A	Utility feed	
					<b>Display Graphics Power Room</b>	
no	no	tested	tested	003176	Panel L6-2	
no	no	tested	tested	003177	Panel L6-1	
no	no	tested	tested	003178	TL6 transformer	
no	no	tested	tested	003179	Panel HM6-1	
no	no	tested	tested	003180	Panel HM6-2	
no	no	tested	tested	003181	Panel H6-1	
no	no	not-t	tested	003182	Panel H6-2	added circuits

Red - Open Problem

Green - Corrected Problem

Brown - Not Inspected

Black - No Problem